

BEFORE THE NEW MEXICO PUBLIC REGULATION COMMISSION

**IN THE MATTER OF PUBLIC SERVICE)
COMPANY OF NEW MEXICO'S)
CONSOLIDATED APPLICATION FOR)
APPROVALS FOR THE ABANDONMENT,)
FINANCING, AND RESOURCE REPLACEMENT)
FOR SAN JUAN GENERATING STATION)
PURSUANT TO THE ENERGY TRANSITION ACT)**

19-____-UT

**DIRECT TESTIMONY
OF
NICK WINTERMANTEL**

July 1, 2019

**NMPRC CASE NO. 19-____-UT
INDEX TO THE DIRECT TESTIMONY OF
NICK WINTERMANTEL**

**WITNESS FOR
PUBLIC SERVICE COMPANY OF NEW MEXICO**

I.	INTRODUCTION AND PURPOSE.....	1
II.	ASTRAPÉ’S ROLE AND THE SERVM MODELING FRAMEWORK USED IN PNM’S RFP EVALUATION.....	5
III.	SERVM MODELING INPUTS AND PARAMETERS	14
IV.	SUMMARY OF OFFERS EVALUATED IN ASTRAPÉ’S MODELING	16
V.	REPLACEMENT RESOURCE EVALUATION AND RESULTS.....	18
VI.	ADDITIONAL CASE SUPPORT.....	28
VII.	CONCLUSIONS.....	29

PNM Exhibit NW-1

Resume of Nick Wintermantel

PNM Exhibit NW-2

Astrapé RFP Evaluation Report

AFFIDAVIT

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1

I. INTRODUCTION AND PURPOSE

2 **Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.**

3 **A.** My name is Nick Wintermantel, and my business address is 1935 Hoover Court,
4 Hoover, AL, 35226.

5

6 **Q. WHAT IS THE PURPOSE OF YOUR TESTIMONY?**

7 **A.** My testimony summarizes the evaluation process Astrapé Consulting (“Astrapé”)
8 used to determine generation resource recommendations to replace San Juan
9 Generating Station (“SJGS”) Units 1 and 4 and the results of that evaluation
10 process. I am including PNM Exhibit NW-2 with my testimony which is a full
11 report of the evaluation performed by Astrapé.

12

13 **Q. PROVIDE A BRIEF OVERVIEW OF WHAT YOUR TESTIMONY**
14 **CONCLUDES.**

15 **A.** My testimony concludes that the replacement resources that meet reliability
16 targets, and when combined provide reasonable risk and costs to customers, are:
17 seven aeroderivative gas units totaling 280 MW,¹ two combined solar battery
18 projects including a total of 60 MW of battery and 350 MW of solar, and two
19 stand-alone battery projects of 40 MW and 30 MW shown in PNM Table NW-1.
20 This combination of resources is the recommended plan submitted by Public
21 Service Company of New Mexico (“PNM” or “Company”) and is discussed as

¹ The 280 MW represents nameplate capacity. The net capability results in 269 MW for modeling purposes.

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 Scenario 1. This set of resources takes advantage of the “best in class” offers, as
2 discussed in PNM Witness Nagel’s testimony, across several technologies
3 including solar, battery, and natural gas resources while alleviating technology
4 risk for customers as discussed in PNM Witness Kemp’s testimony. The selected
5 resources combine supplier-owned purchased power agreements (“PPAs”) and
6 utility-owned Engineer Procure Construct (“EPC”) projects. These replacement
7 resources, combined with the recent Renewable Portfolio Standard (“RPS”) wind
8 resource of 140 MW² and the recent 50 MW PNM Solar Direct project, provide
9 great diversity to PNM’s generation fleet.

10 **PNM Table NM-1 – Replacement Resources in Scenario 1**

Name	Resource Type	Nameplate Capacity	Ownership	Location
Jicarilla	Solar	50 MW	PPA	Rio Arriba
Arroyo	Solar	300 MW	PPA	McKinley
Jicarilla	Battery	20 MW	PPA	Rio Arriba
Arroyo	Battery	40 MW	PPA	McKinley
Sandia	Battery	40 MW	EPC	Bernalillo
Zamora	Battery	30 MW	EPC	Bernalillo
San Juan Gas	Natural Gas	280 MW	EPC	San Juan

11
12 **Q. BY WHOM ARE YOU EMPLOYED AND WHAT IS YOUR POSITION?**

13 **A.** I am a Principal Consultant and Partner at Astrapé, which is a consulting firm that
14 provides expertise in resource planning and resource adequacy to utilities across
15 the United States and internationally.

² See New Mexico Public Regulation Commission Docket No. 19-00159-UT.

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 **Q. PLEASE BRIEFLY SUMMARIZE YOUR EDUCATIONAL**
2 **BACKGROUND.**

3 **A.** I graduated summa cum laude with a Bachelor of Science in Mechanical
4 Engineering from the University of Alabama in 2003 and a Master's degree in
5 Business Administration from the University of Alabama at Birmingham in 2007.
6 A copy of my resume is attached as PNM Exhibit NW-1.

7

8 **Q. PLEASE DESCRIBE YOUR CONSULTING BACKGROUND AND**
9 **EXPERIENCE.**

10 **A.** I have worked in the utility industry for over 19 years. I started my career at
11 Southern Company where I worked in various roles within Southern Power, the
12 competitive arm of the company, and on the retail side of the company within
13 Southern Company Services. In my various roles, I was responsible for
14 performing production cost simulations, financial modeling on wholesale power
15 contracts, general integrated resource planning, and asset management. In 2009, I
16 joined Astrapé as a Principal Consultant and have been responsible for resource
17 adequacy, resource planning, and renewable integration studies across the U.S.
18 and internationally.

19

20 **Q. HAVE YOU PREVIOUSLY TESTIFIED IN UTILITY-RELATED**
21 **PROCEEDINGS?**

22 **A.** I have testified in Georgia and provided written testimony in South Carolina and
23 North Carolina in utility-related proceedings. This is the first time I have

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 presented testimony before the New Mexico Public Regulation Commission
2 (“NMPRC” or “Commission”).
3

4 **Q. PLEASE PROVIDE AN OVERVIEW OF YOUR EXPERTISE**
5 **PERFORMING RESOURCE ADEQUACY AND PLANNING STUDIES.**

6 **A.** Since being employed by Astrapé in 2009, I have managed target reserve margin
7 studies; capacity value studies of wind, solar, storage, and demand response
8 resources; resource selection decisions; and ancillary service studies for
9 integrating renewables. I performed these studies using Astrapé’s proprietary
10 Strategic Energy Risk Valuation Model (“SERVM”) used by utilities and system
11 operators across the U.S. and internationally. More recently, I performed studies
12 for companies seeking to increase their renewable penetrations, similar to PNM,
13 and have worked with our Astrapé team to develop a modeling framework within
14 SERVM to capture reliability, flexibility, and economics of varying resource
15 mixes.
16

17 **Q. CAN YOU PLEASE EXPAND ON THE BUSINESS OF ASTRAPÉ?**

18 **A.** Astrapé is the exclusive licensor of the SERVM model which is used by utilities,
19 system operators, and regulators to perform resource adequacy and planning
20 studies. Astrapé has managed SERVM licenses or performed studies for utilities
21 and regulatory organizations such as the Tennessee Valley Authority, Southern
22 Company, Duke Energy, Entergy, Pacific Gas & Electric, Louisville Gas &
23 Electric, and the California Public Utilities Commission. The SERVM model is

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 also used for resource adequacy by large independent operators such as the
2 Electric Reliability Council of Texas, the Southwest Power Pool, the Alberta
3 Electric System Operator, and the Midwest Independent System Operator.

4
5 **Q. HAVE YOU PERFORMED CONSULTING SERVICES FOR PNM**
6 **BEFORE?**

7 **A.** Yes. I have performed resource adequacy and resource planning studies for PNM
8 since 2013 using the SERVVM model. A significant portion of Astrapé's work was
9 included in the Company's 2017 Integrated Resource Plan ("IRP"), which
10 included reliability and flexibility analysis for the PNM system. PNM now
11 licenses the SERVVM model from Astrapé.

12
13 **II. ASTRAPÉ'S ROLE AND THE SERVVM MODELING FRAMEWORK**
14 **USED IN PNM'S RFP EVALUATION**

15 **Q. BRIEFLY DESCRIBE ASTRAPÉ'S ROLE IN THE RFP EVALUATION.**

16 **A.** After HDR Engineering, Inc. ("HDR") performed its screening evaluation to
17 develop its "best in class" RFP offers, as discussed in the testimonies of PNM
18 Witnesses Fallgren and Nagel, Astrapé was engaged to evaluate combinations of
19 these offers and recommend a set of low-cost replacement resources for PNM that
20 meet reliability targets.

21

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 **Q. EXPLAIN WHY SYSTEM PRODUCTION COST AND RELIABILITY**
2 **MODELING IS REQUIRED TO EVALUATE DIFFERENT**
3 **REPLACEMENT RESOURCE COMBINATIONS.**

4 **A.** The screening analysis performed by HDR analyzed each offer independently and
5 determined the low-cost offer by technology or “best in class,” but did not provide
6 analysis of how the offers performed together or provide insight on how much
7 capacity to take of each technology. Production cost modeling is necessary in
8 order to understand how the range of different technologies perform within the
9 existing PNM generation fleet and with each other over the next 20-year period.
10 More importantly, the SERVVM model assesses system reliability to help ensure
11 there is sufficient capacity and flexibility in each replacement resource
12 combination evaluated. For replacement resource combinations that meet
13 reliability requirements, the total system costs, including all production costs to
14 serve load and the fixed capital and O&M costs of the replacement resources (or
15 offers), are calculated to determine the net present value (“NPV”) of expected
16 costs for each combination over the 20-year period. The costs of each
17 replacement resource combination can then be compared on a NPV basis.

18

19 **Q. BRIEFLY DESCRIBE THE MODELING CHARACTERISTICS**
20 **REQUIRED TO PERFORM PRODUCTION COST AND RELIABILITY**
21 **MODELING ON PNM’S SYSTEM.**

22 **A.** As the PNM system changes due to the retirement of base load resources and
23 higher renewable penetrations, future resource decisions must not only take into

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 account customer economics and reliability during peak demand, but also system
2 flexibility needs. This includes the capability of the system to meet unforeseen
3 net load ramps on an hourly and intra-hour basis. Typical planning studies utilize
4 load shapes and renewable profiles from a single weather year and only simulate
5 average unit performance characteristics. Since flexibility and reliability issues
6 are high impact, low-probability events, many scenarios of load, renewable
7 output, and conventional generator performance should be considered to
8 adequately capture their expected impact. In addition to considering many
9 scenarios to capture the reliability of the system, the production cost model should
10 also commit and dispatch resources chronologically, taking into account resource
11 characteristics such as startup times, ramp rates, minimum up times, and
12 minimum down times. By taking into account these resource characteristics, the
13 flexibility of the system can be assessed.

14
15 **Q. BRIEFLY DESCRIBE THE SERVM MODEL.**

16 **A.** As discussed in PNM Exhibit NW-2, the SERVM model is a chronological
17 production costing model and reliability model that takes into account the
18 uncertainty of weather, load forecast, generator outages, and intra-hour volatility
19 of intermittent resources. Thousands of yearly simulations are performed at 5-
20 minute time steps for each replacement resource combination, which allows the
21 model to calculate both reliability metrics and costs. SERVM respects all unit
22 characteristics including ramp rates, startup times, and minimum up and down

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 times. SERVVM does not have perfect knowledge of net load³ when it makes its
2 commitment and dispatch decisions. This is important since it mimics the
3 uncertainty faced by utility operators.

4
5 **Q. IN SIMPLE TERMS, PLEASE EXPLAIN THE RELIABILITY**
6 **ANALYZED AS PART OF THE EVALUATION.**

7 **A.** While reliability metrics and terms can come across as complex topics, it is
8 actually very simple. A Balancing Authority (“BA”) such as the PNM BA must
9 plan to have enough capacity to serve its peak demand and have enough
10 flexibility or ramping capability in its generation fleet to meet its net load in real
11 time. As more intermittent resources are added to the system, the net load ramps
12 become larger requiring additional generation flexibility. To resolve generation
13 capacity shortages during peak demand periods, new generation capacity must be
14 installed or purchased. To resolve flexibility or system ramping problems,
15 additional online operating reserves are committed. Having additional reserves
16 available allows the system to mitigate the intra-hour and hourly ramps caused by
17 unforeseen solar, wind, and load ramps. Adding more flexible resources can also
18 be used to resolve flexibility problems.

19

³ Net load is defined as gross load minus renewable resources and reflects the load the conventional fleet must serve on a minute to minute basis.

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 **Q. HOW DOES SERV M MEASURE THE RELIABILITY OF THE PNM**
2 **SYSTEM FROM A CAPACITY AND FLEXIBILITY NEED**
3 **STANDPOINT?**

4 **A.** SERV M calculates two reliability metrics for the PNM BA. Both of these metrics
5 use LOLE (“Loss of Load Expectation”), which is a count of the expected number
6 of days per year that load could not be met over the thousands of yearly
7 simulations performed. The first metric (“LOLE_{CAP}”) measures capacity
8 shortfalls, while the second metric (“LOLE_{FLEX}”) measures flexibility shortfalls.


9
10 **Q. PLEASE FURTHER DESCRIBE LOLE_{CAP}.**

11 **A.** The LOLE_{CAP} metric represents the number of loss of load events due to capacity
12 shortages, calculated in events per year. Traditional LOLE calculations only
13 calculate LOLE_{CAP}. PNM Figure NW-2 shows an example of a capacity shortfall
14 which typically occurs across the peak of a day. In this example, all available
15 installed capacity was fully utilized but the load was greater than the generating
16 capacity causing a capacity shortfall. For these events, additional capacity must
17 be added to the system in order to reduce LOLE_{CAP}.

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1
2

**PNM Figure NW-2
LOLE_{CAP} Example**



3

4 **Q. PLEASE FURTHER EXPLAIN LOLE_{FLEX}.**

5 **A.** The LOLE_{FLEX} metric is the number of loss of load events due to system
6 flexibility problems, calculated in events per year. In these events, there was
7 enough capacity installed but not enough flexibility to meet the net load ramps, or
8 startup times prevented a unit coming online fast enough to meet the
9 unanticipated ramps.

10


11 PNM Figure NW-3 shows an LOLE_{FLEX} example occurring intra-hour. These
12 LOLE_{FLEX} events are typically very short in duration and are caused by a rapid
13 drop in solar or wind resource output over a short time interval. Increasing online

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 spinning reserves or adding fast ramping capability resources can help resolve
2 these issues.

3
4

**PNM Figure NW-3
Intra-hour LOLE_{FLEX}**



5

6 **Q. HOW DID YOU ENSURE RELIABILITY METRICS WERE MET FOR**
7 **THE VARIOUS RESOURCE COMBINATIONS?**

8 **A.** Each replacement resource combination modeled was developed to meet or be
9 below the LOLE_{CAP} and LOLE_{FLEX} criteria of 0.2 events per year. If a
10 combination of replacement resources did not meet these criteria, either additional
11 capacity was added or additional online reserves were input into the model. This
12 allows each replacement resource combination to be comparable rather than
13 allowing one combination to provide significantly lower reliability than another.

14

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 **Q. WHY WAS 0.2 EVENTS PER YEAR CHOSEN AS THE RELIABILITY**
2 **CRITERIA FOR LOLE_{CAP} AND LOLE_{FLEX}?**

3 **A.** Based on the size of PNM's system, Astrapé recommended as part of the 2017
4 IRP that PNM target a 0.2 LOLE (two events in ten years) standard at a
5 minimum. The industry-standard reliability threshold is one firm load shed event
6 in ten years. This is known as the '0.1 LOLE' or '1-in-10 LOLE' standard. For
7 small systems with limited interconnections, this level of reliability is difficult and
8 costly to achieve. The simultaneous forced outage of two larger units during peak
9 conditions puts significant risk on smaller systems such as PNM's, compared to a
10 larger system with more than 50 generators.

11

12 **Q. DESCRIBE THE RELATIONSHIP BETWEEN RELIABILITY UNDER A**
13 **LOLE STANDARD AND RENEWABLE CURTAILMENT.**

14 **A.** LOLE events are times when generation cannot meet net load requirements;
15 renewable curtailment occurs when resources are greater than net load causing
16 over-generation periods. During these periods, the system cannot ramp down fast
17 enough to meet net load or all online generators are dispatched at minimum but
18 are still producing more than system net load needs. Renewable curtailment is
19 expected in systems with large renewable penetration and impacts the economics
20 of each replacement resource combination evaluated. In general, as renewable
21 penetration increases, renewable curtailment will increase. For modeling
22 purposes, there was no additional penalty included for renewable curtailment
23 other than the cost associated with generation that was not used to serve load.

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 **Q. WHAT ARE THE IMPLICATIONS OF CAPTURING 5-MINUTE INTRA-**
2 **HOUR VOLATILITY OF LOAD, WIND, AND SOLAR IN THE MODEL?**

3 **A.** By modeling the system on a 5-minute basis and capturing the volatility or
4 unexpected movement of load, wind, and solar, the dispatchable generation fleet
5 is forced to follow net load and absorb this volatility to maintain reliability. This
6 modeling framework quantifies the savings that flexible resources such as battery
7 or fast-start gas resources provide to the system, as compared to slower-starting
8 resources with poor ramping capability. This modeling also captures the
9 additional costs that inflexible resources such as solar and wind have on the
10 system since these resources cause the dispatchable fleet to ramp up and start up
11 more frequently in order to maintain reliability.

12

13 **Q. OVER WHAT TIME HORIZON WERE THE REPLACEMENT**
14 **RESOURCE COMBINATIONS SIMULATED?**

15 **A.** Consistent with PNM's 2017 IRP, the SERVVM analysis was performed over a
16 period of 20 years. Due to the number of iterations required in reliability
17 modeling, study years 2023, 2028, and 2033 were simulated and production costs
18 were interpolated to produce 20-year production costs. Fixed costs, including
19 capital costs, O&M, transmission costs, and fixed gas transportation if applicable,
20 of the replacement portfolio were included over the 20 year period. The
21 expansion plan beyond the replacement resources was held constant across each
22 replacement resource combination analyzed.

23

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 **Q. WHAT IS INCLUDED IN TOTAL SYSTEM NET PRESENT VALUE**
2 **COSTS WITHIN THE MODELING?**

3 **A.** The results are the NPV over 20 years of the annualized production costs, net
4 purchase costs, and fixed costs of the replacement resources. Production costs
5 include all fuel burned, variable O&M costs, startup costs, and CO₂ costs for the
6 entire PNM Balancing Area. To calculate the NPV, Astrapé used PNM's most
7 recent weighted average cost of capital (7.2%) that was approved in the last rate
8 case.

9

10 **III. SERVM MODELING INPUTS AND PARAMETERS**

11 **Q. DID THE COMPANY USE OTHER RESOURCE PLANNING**
12 **MODELING SOFTWARE?**

13 **A.** Yes. PNM also performed simulations with Encompass and PowerSimm.

14

15 **Q. WERE THE MODELING INPUTS USED IN SERVM THE SAME INPUTS**
16 **USED IN THE ENCOMPASS MODELING PERFORMED BY THE**
17 **COMPANY?**

18 **A.** Yes, as shown in detail in PNM Exhibit NW-2, the inputs were aligned to match
19 loads, resources, and fuel forecasts included in the Company's Encompass
20 modeling. As discussed previously, the SERVM model was simulated for the
21 2023, 2028, and 2033 study years. The Company provided an expansion plan
22 beyond the replacement resources which consisted of solar, wind, and battery

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 resources to meet future RPS and carbon targets. In order to ensure the reliability
2 of PNM's system in 2028 and 2033, the magnitude of solar, wind, and battery was
3 adjusted accordingly.

4
5 **Q. WHAT FUEL FORECAST AND CO2 FORECASTS WERE USED?**

6 **A.** See Table 9 in PNM Exhibit NW-2. The natural gas prices are based on a blend
7 of forward pricing and gas pricing forecasts provided by Pace Global ("Pace") for
8 PNM. Gas forwards from April 26, 2019 were utilized for the first 10 years;
9 thereafter, forward pricing was scaled to the Pace forecast curve to project pricing
10 for the next 10 years. CO₂ pricing was derived from Pace Global to reflect a 20-
11 year forecast of national costs per ton of CO₂ emitted.

12
13 **Q. WHAT LOAD FORECAST WAS USED IN THE MODELING?**

14 **A.** See Table 5 in PNM Exhibit NW-2. These load forecasts reflect an update from
15 the 2017 IRP and the Company's latest peak demand and energy forecasts.

16
17 **Q. WHAT NEIGHBORING REGIONS WERE MODELED WITHIN SERVM?**

18 **A.** Neighboring regions adjacent to the PNM BA were modeled. From a capacity
19 standpoint, it is important that the modeling recognizes market assistance during
20 extreme scenarios for PNM. For instance, when PNM's load is higher than
21 expected and several generators are on outage, PNM will make hourly purchases
22 if surrounding neighboring regions have excess capacity and transmission is
23 available. Also, during renewable curtailment hours, there is potential for PNM

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 to sell to these neighbors assuming they are not curtailing renewable resources as
2 well. From discussions with the Company and analysis of historical data,
3 purchases were limited to 150 MW of day ahead purchases and up to 150 MW of
4 non-firm purchases.

5

6 **IV. SUMMARY OF OFFERS EVALUATED IN ASTRAPÉ'S MODELING**

7 **Q. PLEASE PROVIDE A LIST OF THE RFP RESOURCES THAT HDR**
8 **PROVIDED TO YOU FOR MODELING PURPOSES.**

9 **A.** The following Table NW-4 shows the resources that were considered for
10 modeling and provided by HDR. These offers are summarized in Tables 2 – 4
11 from PNM Exhibit NW-2. The offers were the “best in class” offers by
12 technology and were further split into Tier 1 and Tier 2 based on initial rankings
13 performed by HDR. The Tier 1 offers were used to create combinations of
14 replacement resources that would meet an $LOLE_{CAP}$ and $LOLE_{FLEX}$ of
15 approximately 0.2 events per year to ensure system reliability. Capacity was
16 added or removed to achieve the $LOLE_{CAP}$ target and operating reserve
17 assumptions were increased or decreased to achieve $LOLE_{FLEX}$ targets. Tier 2
18 offers, which were ranked further down in HDR's screening evaluation, were
19 used to stress test the least cost combinations resources found in the Tier 1
20 Modeling to understand if more optimal combinations existed. Note that the Tier
21 1 wind resource was already selected as the 2019 RPS resource by PNM due to
22 the early availability of this wind resource in 2020 and the changes in the RPS

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 standard requirements as part of the Energy Transition Act. Therefore this 140
2 MW is included in all replacement resource combinations.

3 **PNM Table NW-4. Summary of Tier 1 and Tier 2 Offers**

Technology	Tier 1/Tier 2	Capacity per Unit
		MW*
Solar	Tier 1	300
Solar	Tier 1	50
Solar	Tier 1	150
Solar	Tier 1	150
Solar	Tier 1	50
Wind	Tier 1	140**
Solar/Battery	Tier 1	300/150
Battery	Tier 1	200
Battery	Tier 1	100
Battery	Tier 1	40
Battery	Tier 1	40
Gas: 4-10 Aero-derivatives	Tier 1	38.44
Gas: Frame	Tier 1	196.1
Gas: 10-20 Recips	Tier 1	16.91
Gas: 1 Aero-derivative	Tier 1	38.44
Wind	Tier 2	400
Wind	Tier 2	200
Solar/Battery	Tier 2	50/20
Solar/Battery	Tier 2	150/40
Battery	Tier 2	40
Battery	Tier 2	100

4 ***Represents solar/battery MW for combined solar/battery technologies**
5 ****Selected as the 2019 RPS Resource and included in all replacement resource**
6 **combinations**
7

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 **V. REPLACEMENT RESOURCE EVALUATION AND RESULTS**

2 **Q. HOW DID ASTRAPÉ DEVELOP REPLACEMENT RESOURCE**
3 **COMBINATIONS WITH THE SHORTLISTED OFFERS FOR THE**
4 **MODELING?**

5 **A.** As discussed in PNM Exhibit NW-2, resource combinations including only
6 renewable options (wind and solar offers) were explored first but were found to
7 not meet reliability requirements unless capacity resources were also added.

8
9 Next, using the Tier 1 offers as discussed above, replacement resource
10 combinations were designed to analyze varying amounts of solar (0 MW to 700
11 MW) with capacity resources including battery and gas technology to capture the
12 full range of possible combinations that could meet reliability. As discussed
13 previously, only the single wind offer selected as the 2019 RPS resource was
14 included in the Tier 1 modeling because the next best wind offers were
15 significantly more costly. These next best wind offers were analyzed as part of
16 the Tier 2 Modeling to understand if those offers were economic. The possible
17 combinations within the Tier 1 Modeling included “bookends” that ran from all
18 gas scenarios to all battery/renewable makeups. Table 23 in Exhibit NW-2 shows
19 all the combinations that were modeled as part of the Tier 1 Modeling. The
20 magnitude of the capacity resource included in each combination was the amount
21 needed to meet reliability thresholds. As noted earlier, “only renewables”
22 scenarios failed system reliability parameters. Each of the capacity resources (gas

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 and battery offers) were similarly analyzed with the varying solar offers (0 to 700
2 MW) to determine reliability and costs of each combination. Combinations of
3 battery options and combinations of gas options were also analyzed such as stand-
4 alone batteries with combined solar/battery and aero-derivatives with
5 reciprocating engines. A total of 81 different replacement resource combinations
6 were simulated as part of the Tier 1 Modeling. If reliability was not met, and
7 there were no more Tier 1 resources for that technology being simulated then Tier
8 2 resources were added. For example, in a few of the all battery/renewable
9 combinations, the Tier 2 battery options had to be added for reliability.

10
11 **Q. WHY WAS IT NECESSARY TO ANALYZE COMBINATIONS OF**
12 **RESOURCES IN THIS MANNER?**

13 **A.** This analysis of potential combinations showed which capacity resource
14 proposals optimally integrated the different amounts of renewable generation
15 amounts while maintaining system reliability. The analysis ultimately indicated a
16 range of how much capacity of each technology should be built. In the initial Tier
17 1 and Tier 2 Modeling, there was no constraint put on capacity for a given
18 technology or capacity size on a single project and therefore the most optimal
19 combination of replacement resources is represented from this modeling.

20
21 **Q. WHAT WAS THE OPTIMAL UNCONSTRAINED REPLACEMENT**
22 **RESOURCE COMBINATION FROM THE TIER 1 MODELING MATRIX**
23 **THAT MET RELIABILITY METRICS?**

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 **A.** The best performing replacement resource combination consisted of 350 MW of
2 solar, 150 MW of battery, and 269 MW of aeroderivative capacity shown in PNM
3 Table NW-5. The combination is represented by the least cost gas, solar, and
4 battery options. There was a substantial increase in energy price for the next
5 cheapest solar option which explains why only 350 MW of solar was selected.

6

7 **PNM Table NW-5. Tier 1 Modeling Optimal Cost Replacement Resources**

	Aeroderivatives	Recips	Frame	Battery	Solar
	MW	MW	MW	MW	MW
Tier 1 Optimal Replacement Resource Combination	269	-	-	150	350

8

9 **Q. HOW DID THE ALL RENEWABLE AND STORAGE (NO GAS)**
10 **COMBINATIONS PERFORM WITHIN THE TIER 1 MODELING?**

11 **A.** The results did not show that an all energy storage and battery combination was
12 the best performing option. While battery is included in the unconstrained best
13 performing option, the costs of battery bids to fill the entire capacity need was
14 more expensive than other low cost gas alternatives.

15

16 **Q. DESCRIBE THE DIFFERENCES IN THE GAS OPTIONS AND WHY**
17 **THE AERODERIVATIVES RESOURCES WERE SELECTED OVER**
18 **OTHER OPTIONS.**

19 **A.** The aeroderivatives and frame offers had similar fixed costs but the
20 aeroderivatives provide more flexibility, especially given their low minimum

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 capacity levels. The reciprocating engines provide more flexibility and slightly
2 cheaper energy costs, but those benefits do not overcome the fixed cost premium
3 on these offers. Across the entire Tier 1 combinations, the aeroderivatives
4 outperformed the frame and reciprocating engine offers.

5
6 **Q. HOW WERE TIER 2 REPLACEMENT RESOURCE COMBINATIONS**
7 **DEVELOPED?**

8 **A.** Tier 2 offers were included in the optimal replacement resource combination
9 found in the Tier 1 Modeling to understand if the economics improved.
10 Additional Tier 2 wind offers were added first which did not improve the
11 economics due to the higher costs of those incremental wind resources. Then,
12 additional hybrid battery/solar and stand-alone battery projects were added. The
13 batteries were allowed to replace both the aeroderivatives and 150 MW battery
14 project. Table 25 in Exhibit NW-2 shows all the combinations that were modeled
15 as part of the Tier 2 Modeling.

16
17 **Q. WHAT WAS THE OPTIMAL UNCONSTRAINED REPLACEMENT**
18 **RESOURCE COMBINATION FROM THE TIER 2 MODELING MATRIX**
19 **THAT MET RELIABILITY METRICS?**

20 **A.** The Tier 2 Modeling produced a combination that improved upon the Tier 1
21 Modeling which is shown in Table NW-6 below. This combination of resources
22 removed a single aeroderivative and added 20 MW of battery which better
23 optimized the capacity need and maintained flexibility on the system. This

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 combination included two combined solar plus battery projects. The first
2 included 300 MW of solar and 150 MW of battery and the second included 50
3 MW of solar and 20 MW of battery.

4

5 **PNM Table NW-6 Tier 2 Modeling Optimal Cost Replacement Resources**

	Aeroderivatives	Recips	Frame	Battery	Solar
	MW	MW	MW	MW	MW
Tier 1 Optimal Unconstrained 2023 Replacement Resources	269	-	-	150	350
Tier 2 Optimal Unconstrained 2023 Replacement Resources	231	-	-	170	350

6

7 **Q. WERE ADDITIONAL OWNERSHIP BATTERY OFFERS CONSIDERED**
8 **AS PART OF THIS ANALYSIS?**

9 **A.** Yes. While the original set of bids in the Tier 1 and Tier 2 Modeling included a
10 large number of PPA bids, the utility owned bids were limited due to a lack of
11 bidders having NM state contractor licenses. Because some original bidders were
12 automatically rejected for that reason, PNM solicited additional utility owned
13 battery proposals through a supplement to the original RFP in order to ensure a
14 range of ownership battery options would be evaluated.

15

16 **Q. DESCRIBE THE ANALYSIS PERFORMED BY ASTRAPÉ TO**
17 **INCORPORATE THE STORAGE OWNERSHIP PROPOSALS**
18 **PROVIDED IN MAY OF 2019.**

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 **A.** The unconstrained optimal combination of resources found in the Tier 2 modeling
2 was modeled with the low cost storage ownership proposals. This was done in
3 multiple combinations by removing gas resources and the battery resources
4 included in Tier 2 least cost combination of resources.

5
6 **Q.** **HOW DID THE STORAGE OWNERSHIP OPTIONS PERFORM?**

7 **A.** In comparison to the optimal unconstrained replacement resource combination,
8 the battery ownership options did not improve the economics. The large 300 MW
9 solar plus 150 MW battery PPA offer was less expensive than the battery
10 ownership options due to the low cost of these options as a result of qualifying for
11 the Investment Tax Credits.

12
13 **Q.** **WHAT RISKS WERE IDENTIFIED IN THE UNCONSTRAINED**
14 **OPTIMAL SET OF REPLACEMENT RESOURCES?**

15 **A.** As part of the Company's review, PNM asked Enovation Partners to review this
16 least cost set of replacement resources with a focus on energy storage since it
17 included a 150 MW battery. Enovation Partners as expressed in Witness Kemp's
18 testimony recommended that initial energy storage implementation by PNM
19 should not be beyond 2% - 5% of the system peak load and that individual
20 projects should be between 10 MW and no more than 40 MW. PNM accepted
21 this recommendation and asked Astrapé for further modeling with this constraint.

22

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 **Q. AS A MODELER THAT LOOKS AT SYSTEM RELIABILITY AND**
2 **RISKS WHAT IS YOUR OPINION OF THAT APPROACH TO LIMITING**
3 **BATTERY SIZES AND OVERALL RESOURCES?**

4 **A.** I support this approach. While the model is an excellent tool to compare
5 reliability and costs, there are attributes and factors that must be considered that
6 don't automatically translate in the model results and must be separately
7 incorporated. One of these is the risk associated with development and
8 deployment of new technology.

9
10 **Q. HOW DID ASTRAPÉ INCORPORATE THIS CONSTRAINT?**

11 **A.** The unconstrained optimal set of resources was modified to maintain smaller
12 energy storage options and limit the energy storage to 130 MW. The Tier 1 and
13 Tier 2 modeling approach demonstrated that the aeroderivative resources were the
14 best capacity resource other than battery capacity and that 350 MW of solar was
15 economic. Next, permutations with the least cost smaller battery offers (both PPA
16 and ownership options) were simulated similar to the Tier 2 Modeling approach.

17
18 **Q. WHAT WERE THE RESULTS OF THIS CONSTRAINED MODELING?**

19 **A.** The results of this analysis are shown in PNM Table NW-7 which sorts the
20 replacement resource combinations that were simulated with these constraints.
21 The top 5 combinations are separated by an NPV of 2 million meaning they are
22 essentially equal from an economics basis. Given the other battery ownership
23 benefits discussed by PNM Witness Kemp and the fact that the differences in

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 economics are negligible, the Company proposes the third replacement resource
2 combination on the list. With battery ownership, PNM will have more flexibility
3 in the operation of those resources as more is learned about the operations through
4 the 20 year period. This proposed plan includes 269 MW of aeroderivatives, 350
5 MW of solar, and 130 MW of battery. The 130 MW of battery consists of a 40
6 MW PPA, 20 MW PPA, 40 MW ownership option, and 30 MW ownership
7 option. This combination is discussed by the Company as Scenario 1.

**PNM Table NW-7 Constrained Replacement Resource Combinations Sorted by
Least Cost**

Resource Replacement Combination	LM6000	PPA Battery	Ownership Battery	Solar	Total NPV	NPV Fixed Costs	NPV Production Costs
	MW	MW	MW	MW	M\$	M\$	M\$
Constrained – 1	269	140	0	350	\$4,677	\$470	\$4,207
Constrained – 2	307	100	0	350	\$4,678	\$461	\$4,217
Constrained - 3 (Proposed Plan)	269	60	70	350	\$4,678	\$472	\$4,206
Constrained – 4	345	40	0	350	\$4,678	\$430	\$4,248
Constrained – 5	307	60	40	350	\$4,679	\$469	\$4,210
Constrained – 6	269	140	0	370	\$4,679	\$482	\$4,198
Constrained – 7	269	60	70	370	\$4,679	\$483	\$4,196
Constrained – 8	269	100	40	350	\$4,683	\$476	\$4,207
Constrained – 9	231	140	30	350	\$4,693	\$485	\$4,208
Constrained – 10	345	60	0	350	\$4,696	\$456	\$4,240
Constrained – 11	231	100	70	350	\$4,698	\$491	\$4,207
Constrained – 12	269	140	0	500	\$4,702	\$449	\$4,253
Constrained – 13	307	100	0	500	\$4,708	\$442	\$4,266
Constrained – 14	345	0	40	350	\$4,711	\$457	\$4,254
Constrained – 15	345	40	0	500	\$4,718	\$430	\$4,288
Constrained – 16	345	60	0	350	\$4,724	\$474	\$4,250
Constrained – 17	383	20	0	350	\$4,726	\$470	\$4,256
Constrained – 18	345	60	0	500	\$4,735	\$456	\$4,280
Constrained – 19	383	40	0	350	\$4,758	\$503	\$4,255

11

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 **Q. IS SERVUM ABLE TO MODEL ALL OF THE UNIQUE BATTERY**
2 **VALUES?**

3 **A.** SERVUM is able to capture the capacity, energy, and ancillary service benefits of
4 battery but is not able to determine transmission and distribution locational
5 benefits. These must then be addressed beyond the model outputs. Not included
6 in my analysis, the Company determined that there was an additional transmission
7 benefit of the ownership options of approximately \$11/kW-yr which would
8 further support the Company's decision to move forward with the combination of
9 replacement resources that included the ownership battery options. These
10 additional benefits were not included in PNM Table NW-7 above.

11

12 **Q. WHAT ADDITIONAL RESOURCE COMBINATIONS DID PNM HAVE**
13 **YOU SIMULATE?**

14 **A.** The Company requested Astrapé run 3 additional scenarios to compare against the
15 proposed plan. These were developed by PNM's resource planning department
16 and respect the 40 MW battery size project limit. These included the following:

17

18 Scenario 1 – This scenario is the proposed plan discussed above. It includes
19 seven aeroderivatives consisting of 269 MW, a combined solar/battery project
20 consisting of 300 MW of solar and 40 MW of battery, a combined solar/battery
21 project consisting of 50 MW of solar and 20 MW of battery, and two standalone
22 battery ownership projects consisting of 40 MW and 30 MW.

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 Scenario 2 - San Juan Location Preference Alternative Scenario – This scenario
2 included the least cost resources in the San Juan Location which included 7
3 aeroderivatives and 1 Frame machine.

4
5 Scenario 3 - No New Fossil Fuel Alternative Scenario – This scenario included
6 the least cost battery projects that were less than 40 MW and renewable resources.
7 It included 500 MW of solar and 11 battery projects summing to 410 MW. The
8 11 different battery projects included 7 PPA options and 4 ownership options.

9
10 Scenario 4 - All Renewable Replacement Scenario – This scenario includes all
11 renewable capacity. This scenario includes all wind and solar PPA projects
12 consisting of 1,200 MW of wind and 975 MW of solar.

13
14 **Q. PLEASE SUMMARIZE THESE ADDITIONAL SCENARIOS AND THEIR**
15 **COSTS COMPARED TO THE RECOMMENDED COMBINATION.**

16 **A.** These scenarios were treated in the same manner as all the other combinations
17 that were simulated as part of the Tier 1 and Tier 2 Modeling and battery
18 constrained approach. The results are shown in PNM Table NW-8 below. Of the
19 4 replacement resource scenarios put forth by the Company, the proposed plan is
20 the most economic. Scenario 2 has an NPV of \$54 million more than Scenario 1
21 while Scenario 3 has an NPV of \$156 million higher than Scenario 1. Scenario 4
22 is even more expensive due to all the renewable curtailment caused in that case
23 but still does not meet reliability criteria. Scenario 3 is unreliable as well and

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 would require additional capacity making the costs in the below table for that
2 scenario lower than what they would be if they were forced to be reliable.

3

4 **PNM Table NW-8 Additional Scenarios Provided by the Company**

Resource Replacement Combination	LM6000	Frame	PPA Battery	Owned Battery	Solar	Wind	Total NPV
	MW	MW	MW	MW	MW	MW	M\$
Scenario 1 – Proposed Plan	269	0	60	70	350	140	\$4,678
Scenario 2 – SJ preferred	269	196	0	0	0	140	\$4,732
Scenario 3 – No Gas	0	0	260	150	500	140	\$4,834
Scenario 4 – All renewable	0	0	0	0	975	1,199	\$5,452

5

6

VI. ADDITIONAL CASE SUPPORT

7 **Q. OUTSIDE OF THE REPLACEMENT RESOURCE EVALUATION, ARE**
8 **YOU SUPPORTING ANY OTHER ANALYSIS AS PART OF THE**
9 **OVERALL CASE?**

10 **A.** Yes, Astrapé provided fuel outputs from the SERVVM runs in the evaluation to
11 PNM Witness Monroy for 2023. This 2023 data was provided for Scenarios 1 – 4
12 discussed above as well as the San Juan coal plant continues scenario.

13

14 **Q. WITNESS MECHENBIER DESCRIBES ADDITIONAL ANALYSIS YOU**
15 **PERFORMED ON SCENARIO 1 IN RELATION TO THE 650 MW**
16 **EXPORT LIMIT. PLEASE EXPLAIN.**

17 **A.** Within the SERVVM simulations, Astrapé performed analysis on a few of the
18 8,760 hourly runs to see what percentage of hours the output of the 269 MW for

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

1 the gas turbine facility; 50 MW associated with Jicarilla Solar 1 (which includes a
2 20 MW battery energy storage facility but will be limited to 50 MW export
3 capability); 300 MW associated with Arroyo Solar (which includes a 40 MW
4 battery energy storage facility but will be limited to 300 MW export capability);
5 and 50 MW associated with Jicarilla Solar 2 for the PNM Solar Direct Project,
6 was above 649 MW. That analysis demonstrated that 0.03% of the hours (less
7 than 3 hours out of 8,760 hours) would have a simultaneous output above 649
8 MW. This is due to the intermittent nature of the 400 MW of solar and the fact
9 that the small aeroderivatives are usually serving some level of ancillary services
10 and not operating at full output. Based on these factors, any curtailment due to
11 transmission is estimated to be minimal.

VII. CONCLUSIONS

14 **Q. BASED ON THE MODELING, WHAT IS ASTRAPÉ'S CONCLUSION?**

15 **A.** Based on the evaluation performed by Astrapé, the proposed plan of replacement
16 resources including 350 MW of solar, 130 MW of battery, and 269 MW of gas
17 meets reliability criteria and provides reasonable costs given the technology
18 constraints imposed. These replacement resources provide a diverse set of
19 resources and take advantage of the lowest cost renewable, battery, and gas offers
20 submitted into the RFP

**DIRECT TESTIMONY
OF NICK WINTERMANTEL
NMPRC CASE NO. 19-____-UT**

- 1 **Q. DOES THIS CONCLUDE YOUR TESTIMONY?**
- 2 **A.** Yes, it does.

GCG#525661